



Certificate

of
Approval
of
Components and Systems

Holder of the Approval:

Texecom Ltd.
Bradwood Court, St. Crispin Way
GB- Haslingden, Lancashire BB4 4PW

This approval

is valid only for the specified component/system as submitted for the test

■ together with the parts listed in enclosure 1

■ documented in the technical papers acc. to enclosure 2 (n/a for systems)

■ for application in the specified fire protection and security installations.

Use of the subject matter of the approval, is subject to the hints/comments of enclosure 3.

The validity of the approval can be extended upon application. Application for extension shall be submitted six months before expiry of the current approval at the latest.

This certificate may only be reproduced in its present form without any modification including all enclosures. All changes of the underlying conditions of this approval shall be reported at once to the VdS Certification Body enclosing the required documentation.

Any advertising with this VdS approved component/system shall reflect the correct contents of the certificate and shall not violate the trade practice rules.

<i>Approval No.:</i>	<i>No. of pages:</i>	<i>Valid from:</i>	<i>Valid to:</i>
G 210102	4	04.11.2010	03.11.2014

Subject matter of the Approval:

Sounders
Type PNC-0001, PNC-0002, PNC-0020, PNC-0041,
PNC-0043

Use:

in Automatic Fire Detection and Fire Alarm Systems

Basis for approval:

DIN EN 54-3:2006-08 - Sounders
DIN EN 54-5:2001-03 + A1:2002-09 - Heat Detectors - Point Detectors, Sect. 4.11 (Software Requirements)
VdS 2344:2005-12 - Procedure Guidelines
VdS 2504:1996-12 - Smoke Detectors, Sect. 5.6



DAT-ZE 005/92

Köln (Cologne), 04.11.2010

Schüngel

Managing Director

i. V. Hesels

Head of the VdS Certification Body

VdS Schadenverhütung GmbH
Zertifizierungsstelle
Amsterdamer Str. 174
D-50735 Köln

A company of the German Insurance Association (GDV)
(German federation of insurance companies)

Accredited by the "Deutsche Akkreditierungsstelle Technik (DATech)" as a certification body for the areas of fire protection and security